

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No. 145 / 1 07/05/2024 / 20 Dated: 30/5/2024

It is certified that an inspection team headed by BIRENDRA SINGH MEHTA

(Name of Officers with designation) from ASSISTANT ENGINEER

(Name of Department/ Office) inspected the SPRING DALES SCHOOL ALMORA

(Name & Address of the school) on 28/5/2024 (date of inspection) and found that the SPRING DALES SCHOOL ALMORA (Name of school) has safe drinking water facilities for the students and members of staff of the institution and is maintaining the hygienic sanitation condition in the school building & the campus as per norms prescribed by the Central/ State/ U.T. Govt.

The above is valid for a period of one year

Signature with Seal:  सहायक अभियन्ता

Name: Birendra Singh Mehta

Designation: Assistant Engineer

Name & Address of the Office / Department :

Uttarakhand Jal
Smithan

To

PRINCIPAL

SPRING DALES SCHOOL ALMORA

(Name & Address of the Institution)

* The filled up certificate should be either in Hindi or English. If it is issued in vernacular language, translated notarized version in English be uploaded along with the original vernacular certificate as a single pdf.



Ujyotsna Sohanlal
Principal

Spring Dales School
Almora Cantt., Almora



District Level Water Quality Testing and Monitoring Laboratory

Uttarakhand Jal Sansthan, Almora

Phone No.: 05962-2234049, E-mail: eealm.uj.s.uk@gmail.com


Test Report ID: 754/UJS/DLWQTML/2023-24


Dated: 26/04/2024


WATER QUALITY TEST REPORT

Name and Address of Organization/ Customer	Spring Dales School, Almora		
Type of Source (Surface Water/ Ground Water/ Sub-Surface Water)	SURFACE WATER	SAMPLE DESCRIPTION	ONE WATER SAMPLE COLLECTED FROM SPRING DALES SCHOOL, ALMORA
Reference Sample Identification:	DLWQTML/UJS/ALM/SDS-01		DATE OF START OF ANALYSIS 24/04/2024
			DATE OF END OF ANALYSIS 26/04/2024
Date and Time of Sample Received: 24/04/2024 01:30PM	Sample Collected by:	Mr. Tarun Bisht (Sampling Assistant)	

SN	Water Quality Parameters Under Chemical Scope	Results	Desirable Limit (BIS)	Permissible Limit (BIS) in the Absence of alternative source	Std. Test Method
1.	pH	6.85	6.5 to 8.5	No Relaxation	IS 3025 Pt-11-2022
2.	Total Dissolved Solids (TDS), mg/L	460	500	2000	IS 3025 Pt-16-2023
3.	Turbidity, NTU	0.89	1	5	IS 3025 Pt-10-2023
4.	Total Alkalinity (as CaCO ₃), mg/L	114	200	600	IS 3025 (Part 23): 2023
5.	Total Hardness (as CaCO ₃), mg/L	174	200	600	IS 3025 (Part 21): 2009
6.	Colour, Hazen	Less than 5	5	15	IS 3025 (Part 4): 2021
7.	Odour	Agreeable	Agreeable	Agreeable	IS 3025 (Part 5): 2022
8.	Taste	Agreeable	Agreeable	Agreeable	IS 3025 (Part 8): 1984
9.	Calcium (as Ca), mg/l	54.4	75	200	IS 3025 (Part 40): 2023
10.	Magnesium (as Mg), mg/l	9.23	30	100	APHA 23 rd -3500-Mg B-2023
11.	Chloride, mg/l	52.47	250	1000	IS 3025 (Part 32), 2019,
12.	Total Coliform, MPN/100ML	Absent	Absent	Absent	APHA 23 rd ED-9223-B
13.	E.coli, MPN/100ML	Absent	Absent	Absent	APHA 23 rd ED-9223-B


(Lab Chemist)
Pappu Bisht
Lab U. J. S., Almora


Ujotsna Sohanlal
Principal


Authorized Signatory
(Assistant Engineer)
Authorized Signatory
District Water Quality Testing
Monitoring Laboratory
Uttarakhand Jal Sansthan, Almora

End of Report

- The results listed refer only to tested sample and applicable parameters.
- This certificate is not to be reproduced wholly or in parts for promotional, public or legal purpose without permission of authority of testing laboratory.
- The samples will be destroyed after fifteen days from the date of issue of test certificate, unless otherwise agreed with customer.
- Result apply to the sample as received.
- The Laboratory is responsible for all the information provided in the report, except when information is provided by the customer.